



NOTES:

1. PRIOR TO ACCEPTANCE, ALL NEW SEWER LINES SHALL BE ISOLATED FROM EXISTING PARTS OF THE SYSTEM BY MEANS OF A MECHANICAL PLUG.
2. PLUG TO REMAIN IN PLACE UNTIL ALL TESTING AND CLEANING IS COMPLETED AND THE SYSTEM HAS BEEN ACCEPTED BY THE CITY.
3. PLUG TO BE SECURED WITH A 3/8" NYLON ROPE AND SPRING CLIP (1500LB RATED). CLIP IS TO BE LOOPED THROUGH MANHOLE STEPS AND CLIPPED TO ROPE.



TEMPORARY SANITARY SEWER MANHOLE PLUGGING DETAIL

STANDARD PLAN:
SS - 040

DATE: **FEB. 2008**

CITY ENGINEER APPROVAL:

Longview: **C.B.**

Kelso: **S.Z.**