



NOTES:

1. CONCRETE BENCHES MUST BE SLOPED AWAY FROM THE MANHOLE WALL BEGINNING IN LINE WITH THE TOP OF THE PIPE AND SLOPED DOWN TO THE SPRING-LINE OF THE PIPE. SLOPE TO BE 1/2" PER FT TYPICAL.
2. ENTRIES SHALL BE KOR-N-SEAL BOOTS.
3. RADIUS OF INVERT MUST HAVE ENOUGH ROOM TO BE ABLE TO INSERT AIR PLUGS AND STANDARD TRACTOR TV EQUIPMENT.



STANDARD SEWER INVERT PLANS FOR MANHOLE

STANDARD PLAN:
SS - 060

CITY ENGINEER APPROVAL:

Longview: **C.B.**

DATE: **FEB. 2008**

Kelso: **S.Z.**