



NOTES:

1. ALL TEMP COLD PATCHING TO BE 1-1/2" MINIMUM DEPTH.
2. CDF MUST CURE FOR A MINIMUM OF 48 HOURS PRIOR TO PAVING OR USE COMPACTABLE CDF.
3. SEE 2008 STANDARD SPECIFICATION SECTION 2-09.3(1)E FOR CDF.
4. TRENCH SHALL BE PLATED UNTIL CDF IS CURED FOR TEMP OR PERMANENT PATCH.
5. PLATE TO BE SECURED BY METHOD APPROVED BY ENGINEER.



ARTERIAL TRENCH RESTORATION

STANDARD PLAN: ST - 010		CITY ENGINEER APPROVAL:	
DATE: FEB. 2008		Longview: C.B.	
		Kelso: S.Z.	