



FOR PIPE ZONE
SEE SS-240.

NOTES:

1. ALL MATERIALS EXCEPT A.C.P. AND BEDDING MATERIAL SHALL BE COMPACTED IN 6-INCH MAXIMUM LIFTS TO 95% DENSITY AS DETERMINED BY ASTM D1557.
2. TRENCH SHALL BE PLATED UNTIL PAVED.
3. PLATE TO BE SECURED BY METHOD APPROVED BY ENGINEER.



RESIDENTIAL TRENCH RESTORATION

STANDARD PLAN:
ST - 020

CITY ENGINEER APPROVAL:

Longview: **C.B.**

DATE: **FEB. 2008**

Kelso: **S.Z.**