



STANDARD CROSS SECTION

CSTC SHALL BE PLACED BENEATH CURB & GUTTER TO A DEPTH OF 6" MINIMUM & SHALL BE COMPACTED TO 95%.



MONOLITHIC CURB FOR SIDEWALKS & RAMPS

STANDARD PLAN:
ST - 100

CITY ENGINEER APPROVAL:
Longview: **C.B.**

DATE: **FEB. 2008**

Kelso: **S.Z.**