



#### NOTES:

1. ALL FITTINGS SHALL BE BRASS.
2. NO FITTING ALLOWED FROM MAIN TO SETTER.
3. METER LAYING LENGTH:  $1 \frac{1}{2}" = 13"$   
 $2" = 17"$   
PLUS  $\frac{1}{2}"$  FOR GASKETS
4. ALL METERS SHALL READ IN CUBIC FEET.
5. CONTRACTOR OR DEVELOPER WILL SUPPLY WATER METER TO CITY FOR TESTING PRIOR TO INSTALLATION.
6. METER SIZE TO BE APPROVED BY THE CITY.
7. METER TO BE REMOTE READ TYPE.
8.  $1 \frac{1}{2}"$  METERS WILL REQUIRE  $2" \times 1 \frac{1}{2}"$  METER FLANGE REDUCERS.
9. METER BOX LIDS SHALL BE TOUCH READ APPLICATION WITH PLUG IN KNOCK-OUT.
10. FINAL GRADE ADJUSTMENT SHALL BE PERFORMED BY MODIFYING & STACKING BOXES.

## 2" IRRIGATION WATER SERVICE

STANDARD PLAN:  
**W - 030**

DATE: **FEB. 2008**

CITY ENGINEER APPROVAL:

Longview: **C.B.**

Kelso: **S.Z.**