



NOTES:

1. ALL FITTINGS SHALL BE FLANGED.
2. VAULT SHALL BE UTILITY VAULT OR EQUAL.
3. DOORS TO BE LW HHD-1 OR EQUAL AND LEAK PROOF.
4. ALL VAULT PENETRATIONS TO BE SEALED WITH LINK SEAL OR EQUAL.
5. LID TO BE 36 x 60 LW HHD-1 HYDRAULIC LIFT ASSISTED.
6. KNOCKOUTS NOT ALLOWED IN VAULT HATCH TO DRAIN OUTSIDE VAULT.
7. 50-01 CLA VALVE WITH INDICATOR STEM.
8. RELIEF STATION NOT TO BE LOCATED IN TRAFFIC AREAS.
9. MINIMUM LID SIZE 36" x 60".
10. ALL THRUST BLOCKS TO BE CLASS 4000 CONCRETE.
11. VAULT TO BE ABOVE FINISHED GRADE MIN. 3" - MAX. 6".
12. VAULT SHOP DRAWING REQUIRED PRIOR TO ORDERING MATERIALS.

SECTION A - A



2" - 6" TYPICAL PRESSURE RELIEF STATION

STANDARD PLAN:
W - 130
DATE: **FEB. 2008**

CITY ENGINEER APPROVAL:
Longview: **C.B.**
Kelso: **S.Z.**