


OPERATING NUT HEIGHT
12" MIN. - 30" MAX.
BELOW FINISHED GRADE



NOTES:

1. ALL WELDS SHALL BE $\frac{1}{4}$ " FILLET WELDS FOR FULL LENGTH OF CONTACT BETWEEN COMPONENTS.
2. DIAMETER OF CENTERLING PLATE ASSEMBLY SHALL BE $\frac{1}{4}$ " LESS THAT THE INSIDE DIAMETER OF THE VALVE BOX RISER SECTION.
3. SECURE TO OPERATING NUT WITH TWO $\frac{3}{8}$ " SET SCREWS (STAINLESS STEEL).



VALVE OPERATING EXTENSION

STANDARD PLAN:
W - 240

DATE: **FEB. 2007**

CITY ENGINEER APPROVAL:

Longview: **C.B.**

Kelso: **S.Z.**