



NOTES:

1. REFER TO CITY STANDARD DETAIL W-430 FOR INSTALLATION REQUIREMENTS THAT APPLY TO ALL BACKFLOW PREVENTION ASSEMBLIES.
2. ASSEMBLY SHALL BE INSTALLED ABOVE GROUND IN A HEATED AND / OR INSULATED ENCLOSURE CAPABLE OF PROVIDING YEAR-ROUND FREEZE PROTECTION, SIZED TO MEET THE CLEARANCE REQUIREMENTS SHOWN IN THE DETAIL.
3. PIPE STANDS TO BE STANDON S76 OR EQUIVALENT FLANGE STYLE, EITHER GALVANIZED OR MADE OF STAINLESS STEEL.
4. VERTICAL UPRIGHTS SHALL BE FLANGED SPOOLS OR BE RESTRAINED JOINT WITH STAINLESS STEEL RODS.
5. SLAB SHALL EXTEND 12" LARGER THAN ENCLOSURE FOOTPRINT, ALL THE WAY AROUND.



DOUBLE CHECK VALVE ASSEMBLY, LARGE, ABOVE GROUND

STANDARD PLAN: W - 330	CITY ENGINEER APPROVAL:
DATE: FEB. 2008	Longview: C.B. Kelso: S.Z.