



END ELEVATION

SIDE ELEVATION

NOTES:

1. REFER TO CITY STANDARD DETAIL W-430 FOR INSTALLATION REQUIREMENTS THAT APPLY TO ALL BACKFLOW PREVENTION ASSEMBLIES
2. ASSEMBLY SHALL BE INSTALLED ABOVE GROUND IN A HEATED AND/OR INSULATED ENCLOSURE CAPABLE OF PROVIDING YEAR-ROUND FREEZE PROTECTION, SIZED TO MEET THE CLEARANCE REQUIREMENTS SHOWN IN THE DETAIL
3. VERTICAL UPRIGHTS SHALL BE FLANGED SPOOLS OR BE RESTRAINED JOINT WITH STAINLESS STEEL RODS
4. SLAB SHALL EXTEND 12" LARGER THAN ENCLOSURE FOOTPRINT, ALL THE WAY AROUND



DOUBLE CHECK VALVE ASSEMBLY, N-PATTERN

STANDARD PLAN:
W - 340
DATE: **FEB. 2008**

CITY ENGINEER APPROVAL:
Longview: **C.B.**
Kelso: **S.Z.**