



NOTES:

1. REDUCED PRESSURE BACKFLOW ASSEMBLY SHALL BE INSTALLED IN A LOCATION APPROVED BY THE CITY.
2. REDUCED PRESSURE BACKFLOW ASSEMBLY SHALL BE INSTALLED HORIZONTAL AND PLUMB.
3. ASSEMBLY SHALL BE INSTALLED ABOVE GROUND IN A HEATED AND/OR INSULATED ENCLOSURE CAPABLE OF PROVIDING YEAR-ROUND FREEZE PROTECTION, SIZED TO MEET THE CLEARANCE REQUIREMENTS SHOWN IN THE DETAIL.



N-PATTERN REDUCED PRESSURE BACKFLOW ASSEMBLY

STANDARD PLAN:
W 390 - L

CITY ENGINEER APPROVAL:

DATE: **FEB. 2008**

Longview: **C.B.**

Kelso: