

Additional Utility Requirements:

Maintain 4 foot horizontal separation and 12 inches vertical separation between all facilities installed around City utilities. Above ground utilities such as street lights, fire hydrants, Air vac stations, control panels etc. required a five-foot separation from new construction, relocations, driveways etc. The permittee shall pothole all known utilities to determine depth and location prior to installation of new facilities. ACP pipe and all non-locatable pipes will need to be potholed by hand digging.

Arterial and collector streets require CDF backfill unless otherwise approved by the Engineering Department.

All striping or channelization disturbed by construction shall be replaced in kind within two weeks of removal.

All roadway crossings must be at 90 degrees to the centerline.

All erosion control and inlet protection shall be in accordance with the City of Longview Storm water Ordinance and maintained daily.

All required saw cuts shall be full depth and parallel to the trench or panel as directed by the Engineering Department. No rough or spawled edges will be allowed.

All work to be completed to the satisfaction of the City of Longview and any costs incurred by the City to correct non-compliant work shall be reimbursable to the City of Longview upon request.

No sewer tap shall be located closer than seven feet to any manhole.

Water/Sewer construction shall meet the department of ecology separation requirements.



GENERAL PERMIT PROVISIONS (3 OF 3)

STANDARD PLAN:
PN - 052-L

CITY ENGINEER APPROVAL:

Longview: **C.B.**

DATE: **FEB. 2008**

Kelso: