



W, SIDEWALK WIDTH = WIDTH PER PLANS, 5' MIN.  
 L, SIDEWALK PANEL LENGTH = W

**NOTES:**

1. CONCRETE MIX SHALL BE 3000 PSI COMMERCIAL GRADE.
2. CLEAR CONCRETE SEALER SHALL BE APPLIED WITHIN (2) TWO HOURS AFTER FINISHING IS COMPLETE.
3. JOINTS IN SIDEWALK MUST ALIGN WITH JOINTS IN CURB.
4. PLACE TRANSVERSE CONTRACTION JOINTS AT INTERVALS EQUAL TO THE WIDTH OF THE SIDEWALK.
5. SURFACE EDGING (SHINER) SHALL BE 3" WIDE SMOOTH BORDERS EITHER FOLLOWING EXISTING PATTERN OR AS SHOWN . (ALSO USED ON ALL JOINTS).
6. MATCH EXISTING SCORE AND SHINER MARKS WITH SURROUNDING SIDEWALK IN AREA OR AS DIRECTED BY INSPECTOR.
7. FINISH SHALL BE BROOMED TRANSVERSE TO THE RUN OF THE SIDEWALK.
8. FOR WIDENING AROUND MAILBOXES AND OTHER OBSTRUCTIONS IN THE SIDEWALKS SEE ST-100.
9. FULL PANEL REPLACEMENT REQUIRED FOR ALL DAMAGED OR VANDILIZED CONCRETE. NO GRAFFITI DAMAGE OR REPAIRS WILL BE ACCEPTED.

N.T.S.



**CITY OF KELSO**  
 DEPARTMENT OF  
 COMMUNITY DEVELOPMENT  
 & ENGINEERING

**SIDEWALKS**

**CITY ENGINEER APPROVAL: Michael Kardas, P.E.**

x

STANDARD PLAN NO.

**KST-070-21**

DATE:

**MAY 2021**