

NOTES:

- 1. METER BOX SHALL BE ARMORCAST A6001640PCX12-KO WITH A A6001947TDZ-H7 COVER AND 00361121 CAST IRON DROP IN LID, OR APPROVED EQUAL.
- 2. METER SETTERS SHALL BE FORD VBB77-18HB-11-77-15-5-NL OR APPROVED EQUAL.
- 3. ALL FITTINGS SHALL BE U.S. BRASS.
- 4. THE SERVICE LINE SHALL BE CONTINUOUS WITHOUT ANY ADDITIONAL SPLICES, JOINTS OR COUPLINGS.
- 5. METER LAYING LENGTH:

2" = 17"

PLUS ½" FOR GASKETS

- 6. $1\frac{1}{2}$ " METERS REQUIRE 2" x $1\frac{1}{2}$ " METER FLANGE REDUCERS.
- 7. FINAL GRADE ADJUSTMENT SHALL BE PERFORMED BY MODIFYING & STACKING BOXES.
- 8. SERVICE TUBING SHALL BE 250 PSI RATED (SDR7), BLUE, HDPE OR TYPE K COPPER.
- 9. ALL FITTINGS CONNECTING TO METER SETTER SHALL BE GASKETED.
- 10. CITY SHALL PROVIDE WATER METER.

N.T.S.



$1-\frac{1}{2}$ " AND 2" WATER SERVICE

STANDARD PLAN NO.

CITY OF KELSO

DEPARTMENT OF

COMMUNITY DEVELOPMENT

& ENGINEERING

CITY ENGINEER APPROVAL: Michael Kardas, P.E.

KW-030-21

. 0110/1/0

MAY 2021